



ADDENDUM NO. 01
August 06, 2018

To Drawings and Specifications dated June 29, 2018.

RIVER OAKS ELEMENTARY SCHOOL – FA/IA Upgrades and Paint and Repair Package
Galt Joint Union Elementary School District

Prepared by: **PBK**
2520 Venture Oaks Way, Suite 440
Sacramento, California 95833

PBK Project Nos.: 17232

- A. Receipt of this Addendum shall be acknowledged on the Bid Form.
- B. This Addendum forms part of the Contract documents for the above referenced project and shall be incorporated integrally therewith.
- C. Each bidder shall make necessary adjustments and submit this proposal with full knowledge of all modifications, clarifications, and supplemental data included therein. Where provisions of the following supplemental data differ from those of the original Contract Documents, this Addendum shall govern.

GENERAL INFORMATION

Item No. 1 With this Addendum, we're adding the C-10 Electrical Contractor License and also clarifying the licenses. If you are a sub-contractor you must perform your work under a General Contractor that is qualified to perform the entire scope of work.

SPECIFICATIONS

Item No. 2 Section 1 - Notice to Contractors Calling for Bids; The date and time for the Bid opening has been changed to September 10, 2018 at 2:00 pm.

Item No. 3 Contractor shall address the following changes in the Shop Drawings required per 266113 1.6 A.4.

- 1. Revise the fire alarm power supply to Silent Knight 5496.
- 2. Revise the originating location for the following fire alarm speaker circuits. See sheet E4.05 of electrical drawings for reference:
 - a. Spk-3 from FACP shall originate from AMP-2, circuit 3 in Bldg. B
 - b. SPK-2 from FACP shall originate from AMP-2, circuit 4 in Bldg. B
 - c. SPK-1 from FACP shall originate from AMP-3, circuit 3 in Bldg. G

END OF ADDENDUM NO. 01